



Flint Hills Resources, LP Work Order Details

Org: FHR-PE
Site: PE

WO #: PE49364

WO Desc: Top manual valve to R17 CAT Tank is leaking

Parent WO#:

WO Long Desc:

WO Priority: 1

Location: E-T-R17C

REACTOR 17 CATALYST TANK - 6TH FLOOR

Asset: 1348000

REACTOR 17 CATALYST TANK - 6TH FLOOR

Asset Service:

Entry Date: 12/7/2013

WO Status: CLOSE

Action Code: CORR

Project #:

Originator: BOB HORNBECK

Status Date: 6/8/2014

Work Type: CM

Failure Class: TANK

Job Plan:

Planned Start:

Actual Start: 12/9/2013

Review Date:

PM/Bundle:

Planned Completion:

Actual Completion: 12/9/2013

Plant Information

RC: PERC01

Planner: JOSEPH VITTONI

MOC#:

When Code: RT

Lead Craft: MECH

MOC Status:

P&ID:

MOC Desc:

SIR/EIS Required:

Work Actuals Materials

Task ID	Stock No.	Noun Qualifier	PO	PO Line Num	Quantity
	400043	KIT, REBUILD, FOR APOLLO 1" BALL VALVE, P/N 83R-005-01.			1

Completed by Emp #: _____

Signature: _____